



Product Service

# CERTIFICATE


No. Z2 15 11 82355 009

**Holder of Certificate:** Hanover Solar GmbH

Herrenstrasse 13  
30159 Hannover  
GERMANY



**Certification Mark:**



**Product:**

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 701261504903-00

**Valid until:** 2020-10-22



**Date,** 2015-11-13

( Zhulin Zhang )

Page 1 of 2



Product Service

## CERTIFICATE

No. Z2 15 11 82355 009

### Model(s):

HS275M-36D, HS280M-36D, HS285M-36D, HS290M-36D,  
HS295M-36D, HS300M-36D, HS305M-36D, HS310M-36D,  
HS315M-36D, HS320M-36D, HS325M-36D, HS330M-36D,  
HS230M-30D, HS235M-30D, HS240M-30D, HS245M-30D,  
HS250M-30D, HS255M-30D, HS260M-30D, HS265M-30D,  
HS270M-30D, HS275M-30D, HS210M-27D, HS215M-27D,  
HS220M-27D, HS225M-27D, HS230M-27D, HS235M-27D,  
HS240M-27D, HS245M-27D.

### Parameters:

Rated Output Power  
at STC:

275W, 280W, 285W, 290W,  
295W, 300W, 305W, 310W,  
315W, 320W, 325W, 330W,  
230W, 235W, 240W, 245W,  
250W, 255W, 260W, 265W,  
270W, 275W, 210W, 215W,  
220W, 225W, 230W, 235W,  
240W, 245W.

Construction:

Framed, with Junction box,  
Cable and Connectors.

Application Class:

Class A

Maximum System Voltage:

1000 V DC

Fire Safety Class:

Class C

PID Test Condition:

±1000V DC, 96 h, 85% RH, 85°C

### Tested according to:

IEC 61215(ed.2)  
IEC 61730-1(ed.1);am1;am2  
IEC 61730-2(ed.1);am1  
PPP 58042B:2015

### Production Facility(ies):

91664